

Testing organisation:

Name: Filtrair Filtrationgroup
 Address: De Werf 16, 8447 GE Heerenveen, The Netherlands

GENERAL

Report No.: 20-607
 Supervisor: KvdM
 Test(s) requested by: Filtrair

Date of report: 11-6-2020

DEVICE TESTED

Model: C3-300
 Type of media: synthetic
 Net effective filtering area: 1,0m²

Manufacturer: Filtrair
 Construction: roll media

TEST DATA AND ATTACHED TEST ID NUMBERS

Test air flow rate: 900m³/h
 Temperature: 21°C
 Rel. humidity: 35%
 Test aerosol: n.a.

Loading dust: ISO 12103 A2 fine

RESULTS



Initial pressure differential: 14Pa**
 Initial grav. arrestance: 92%
 Efficiency values $e_{PM_1} = 4\%$
 Min. efficiencies $e_{min}PM_1 = 3\%$

Final pressure differential: 300Pa
 Test dust capacity: 900g
 $e_{PM_{2.5}} = 10\%$ $e_{PM_{10}} = 52\%$
 $e_{min}PM_{2.5} = 8\%$

ISO rating: ISO ePM1 -

ISO ePM2.5 - ISO ePM 10 50% *

Remarks: * @ 0,6 m/s **@ 0,25 m/s



NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot by themselves be quantitatively applied to predict filtration performance in all "real life" environments.